

Technical-approval-with-product certificate K25545/03



Issued 2021-10-15 Replaces K25545/02 Page 1 of 3

Flexalen PB System

STATEMENT BY KIWA

With this technical-approval-with-product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Thermaflex Isolatie B.V.

as specified in this technical-approval-with-product certificate and marked with the Kiwa[®]-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL K17401 part A "Flexible piping systems intended for transport of hot and cold drinking water" dated 16-04-2004.

Within the framework of this technical-approval-with-product certificate Kiwa does not impose any inspections with regard to the production of other parts of the (product), nor the manufacturing of the (product) itself.

Ron Scheepers Kiwa

Publication of this certificate is allowed. Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V. Sir Winston Churchilllaan 273 Postbus 70 2280 AB RIJSWIJK The Netherlands Tel. +31 88 998 44 00 Fax +31 88 998 44 20 NL.Kiwa.info@Kiwa.com



Thermaflex Isolatie B.V. Veerweg 1 5145 NS WAALWIJK Postbus 531 5140 AM WAALWIJK Tel. +31 (0)416 567777

Company

Certification process consists of initial and regular assessment of: • quality system

product

•

K25545/04

Flexalen PB System

TECHNICAL SPECIFICATION

Subject

Flexalen PB System

Product characteristics

The product complies to BRL K17401 part A: Flexible piping systems intended for transport of hot and cold drinking water.

The system consists of:

- PB pipes manufactured by Thermaflex Isolatie B.V. (certificate K25543);
- PB Fittings (socket fusion, butt fusion and elektro fusion fittings) manufactured by Thermaflex Isolatie B.V. (certificate K25544);

Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
16	2,2
20	2,8
25	2,3
32	3,0
40	3,7
50	4,6
63	5,8
75	6,9
90	8,2
110	10,0
125	11,4
140 (a)	12,7
160 (a)	14,6
225 (a)	20,5

Colour: gray.

Remarks: (a) these dimensions are exclusively certified according to BRL K536-C Plastics piping systems of PB intended for transport of hot and cold drinking water.

Fitness for contact with drinking water

The pipes and fittings used in this system are approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"; published in the Government Gazette). The criteria for these hygienic aspects are recorded in the respective product certificates.

MARKING

The products shall be marked with the Kiwa-mark.

Pipes

- The minimum required marking on the pipes shall be:
 - KIWA Sor * + class DH1/8 bar for K17401/K536-C (pipes) 2/10 bar ;
 - material identification: PB;
 - the build up of the pipe; PB;
 - certificate number of accompanying technical approval-with-product certificate of the piping system;
 - the manufacturer's name, trade name, system name or logo;
 - nominal outside diameter in mm;
 - nominal wall thickness of the pipe in mm;
 - production code.

The realization of the marks is as follows: clearly, durable and indelible at intervals of not more than 2 meters.

Technical-approval-with-product certificate

page 3 of 3

Flexalen PB System

*) for smaller diameters permitted by Kiwa.

Fittings

The minimum required marking on the fittings shall be:

- KIWA Sor on small products or content of the smallest packaging unit)**;
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clearly, durable and indelible.

The smallest packaging unit of the fittings are provided with at least the following information:

- . KIWA 🎬
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;

K25545/04

- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clearly, durable and indelible on every packaging.

*) for small fittings marking with only KK is permitted.

**) only after approval by Kiwa.

LOGISTICS

Production and assembly of the system is laid down in the annex of the certification agreement.

APPLICATION AND USE

The medium pipes and fittings are designed for drinking water installations with a lifetime of 50 years at an operating temperature profile according to class 2 of NEN-ISO 10508 and an allowable working pressure of maximum 8/10 bar.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Thermaflex Isolatie B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage, transport and processing methods.